



Product Service

Attestation of Conformity

No. N8A 099333 0047 Rev. 01

Holder of Certificate: **LONGi Green Energy Technology Co., Ltd.**
No. 388, Middle Hangtian Road
Chang'an District
710100 Xi'an City, Shaanxi
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704061802026-01

Date, 2019-01-25 (Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®



Product Service

Attestation of Conformity

No. N8A 099333 0047 Rev. 01

Model(s):

LR6-72HV-xxxM,(xxx=320 to 350 in step of 5);
 LR6-60HV-xxxM,(xxx=270 to 300 in step of 5);
 LR6-72PH-xxxM,(xxx=340 to 385 in step of 5);
 LR6-60PH-xxxM,(xxx=280 to 320 in step of 5);
 LR6-72MPH-xxxM,(xxx=340 to 380 in step of 5);
 LR6-60MPH-xxxM,(xxx=280 to 320 in step of 5);
 LR6-72HPH-xxxM,(xxx=350 to 405 in step of 5);
 LR6-60HPH-xxxM,(xxx=295 to 335 in step of 5);
 LR6-72HH-xxxM,(xxx=315 to 385 in step of 5);
 LR6-60HH-xxxM,(xxx=265 to 320 in step of 5);
 xxx is standing for rated output power at STC.

Parameters:

Application Class:	Class A
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute. No.10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P.R.China.
Construction:	Framed, with Junction box, cable and connector.

Tested according to:

EN 61730-1:2007/A11:2014
 EN 61730-2:2007/A1:2012

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.