

# Unit Certificate



FGW TG8 EZE

www.tuv.com  
ID 190000000

No.: 968/GI 1319.01/22

Grid Integration of Distributed Energy Resources

**Certificate Holder** KOSTAL Solar Electric GmbH  
Hanferstr. 6  
79108 Freiburg  
Deutschland

**Manufacturer** see certificate holder

**Subject** PV Converters  
PIKO CI 50, PIKO CI 60

**Codes and Standards** VDE-AR-N 4110:2018  
FGW TR 3:2018 Revision 25

FGW TR 4:2019 Revision 9  
FGW TR 8:2019 Revision 9

**Scope and result** The power generating units mentioned above meet the requirements of VDE-AR-N 4110:2018-11. The conformity is declared by following documents:  
Report-No.: 968/GI 1319.01/22, dated 2022-02-15  
Validation Report-No.: 968/GI 1319.02/22, dated 2022-02-15  
Test Report No. CN21FTOE 003, dated 2021-12-31

The manufacturer has provided proof of certification of the quality management system of his production facility in accordance with ISO 9001 or is subject to production monitoring.

**Specific provisions** The deviations and conditions for conformity according to the evaluation report must be observed. The corresponding conditions and deviations are listed on page 2 of the certificate.

Valid until 2026-09-10

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT GI3 V1.0:2017 in its actual version, whose results are documented in Report No. 968/GI 1319.01/22 dated 2022-02-15. This certificate is specifically valid for the above mentioned system only. It becomes invalid, if any unapproved changes are implemented without prior assessment/approval by the certification body. Authenticity and validity of this certificate can be verified through the above indicated QR-code or at <http://www.fs-products.com>.

**TÜV Rheinland Industrie Service GmbH**

Bereich Automation  
Funktionale Sicherheit

Am Grauen Stein, 51105 Köln

Köln, 2022-02-17

Certification Body Safety & Security for Automation & Grid

Dr. Alf Assenkamp

# Unit Certificate

Nr.: 968/ GI 1319.01/22

Grid Integration of Distributed Energy Resources

## Technical data of the PGU:

Typ:	PIKO CI 50	PIKO CI 60
Rated active power:	50 kW	60 kW
Max. apparent power:	55 kVA	66 kVA
Rated voltage:	400 V <sub>AC</sub>	400 V <sub>AC</sub>
Nominal frequency:	50 Hz	50 Hz
Minimum required short-circuit power (only for type 1 PGU):	N/A	N/A
Software-Version:	600101	

## Validated Simulation Model:

Reference name: Kostal\_rel\_v1.pfd

MD5 Checksum: 87C75025D4EE26ABEAC94BEE32968F8D

Simulation platform: DIgSILENT PowerFactory 2021

## The following deviations and restrictions apply:

None

The following:

- The certified product does not provide a test terminal. A connecting terminal plate has to be installed separately, if necessary.
- Due to missing display, an appropriate device (e.g. PC) to check the protection functions of the certified product has to be provided on demand.

# Unit Certificate

Nr.: 968/ GI 1319.01/22

Grid Integration of Distributed Energy Resources

## Schematic overview of the PGU:

